



### Post Remediation Results Exceedance Table

Of the 1 sample collected on 1/12/2022 at Mahopac High School, **1 (100%)** had lead concentrations that exceeded 15 ppb. The water sample was collected several days after a building water system flush was performed. The table below details the sample location, laboratory result and the previous results for reference.

Mahopac High School - Mahopac School District								
Date	Sample ID	Floor	Location	Lead Level (ppb)	Lead Level (ppb) 12/15/2021	Lead Level (ppb) 1/15/2021	Lead Level (ppb) 12/2/2020	Initial Lead Level (ppb) 10/7/2020
1/12/2022	01-136S-CF-P-09-R2	1	Room 136-S, Laundry closet, Class sink 9	19.1	16.3	30.7	54.2	62.7