

Final 2021 Lead In Water Exceedance Levels (After Remediations)

Mahopac High School, 4th Round Post-Remediation Sampling Results				
Sample Date	Sample ID	Floor	Location	Lead Level (ppb)
1/12/2022	01-136S-CF-P-09-R2	1	Room 136-S, Laundry closet, Class sink 9	19.1

Mahopac Middle School, 4th Round Post-Remediation Sampling Results				
Sample Date	Sample ID	Floor	Location	Lead Level (ppb)
1/12/2022	02-Nurse-NS-P-02-R2	1	Nurse's office bathroom, Nurse sink 2	66.0

Signage is placed on locations that still have exceedances “Handwashing only”