



Post Remediation Results Exceedance Table

Of the 1 sample collected on 1/12/2022 at Mahopac Middle School, **1 (100%)** had lead concentrations that exceeded 15 ppb. The water sample was collected several days after a building water system flush was performed. The table below details the sample location, laboratory result and the previous results for reference.

Mahopac Middle School - Mahopac School District								
Date	Sample ID	Floor	Location	Lead Level (ppb)	Lead Level (ppb) 12/15/2021	Lead Level (ppb) 1/15/2021	Lead Level (ppb) 12/2/2020	Initial Lead Level (ppb) 10/17/2020
1/12/2022	02-Nurse-NS-P-02-R2	1	Nurse's office bathroom, Nurse sink 2	66.0	97.9	50.3	39.5	55.8