



Post Remediation Results Exceedance Table

Of the 22 samples collected on 1/15/2021 at Lakeview Elementary School, 2 (9.1%) had lead concentrations that exceeded 15 ppb. The water samples were collected several days after a building water system flush was performed. The table below details the sample locations, laboratory results and the previous results for reference.

Lakeview Elementary School - Mahopac School District						
Date	Sample ID	Floor	Location	Lead Level (ppb)	Lead Level (ppb) 12/2/2020	Initial Lead Level (ppb) 10/9/2020
1/15/2021	01-017-BF-SSP-06	1	Room 17, Classroom faucet, 6	29.3	46.8	25.2
1/15/2021	00-WEI-BF-SSP-16	Basement	Weight room bathroom, Bathroom sink, 16	15.2	23.2	20.7