


- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response requires
 further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Building and Grounds Maintenance Checklist

Name:	John	Celhor			
School: E2	ZABETH	Shelton	Elemen.	tary	School
Room or Area:	All		Date Completed:		22/24
Signature:		/ 7		<u>~~~</u>	

1. BUILDING MAINTENANCE SUPPLIES	Yes	No	N/A
1a. Developed appropriate procedures and stocked supplies for spill contra	ol •		
1b. Reviewed supply labels	🗬		ч
Ic. Ensured that air from chemical and trash storage areas vents to the outdoors			۵
1d. Stored chemical products and supplies in sealed, clearly labeled containers			
1e. Researched and selected the safest products available			
If. Ensured that supplies are being used according to manufacturers' instructions			
lg. Ensured that chemicals, chemical-containing wastes, and containers a disposed of according to manufacturers' instructions	re _	а	
1h. Substituted less- or non-hazardous materials (where possible)			
1i. Scheduled work involving odorous or hazardous chemicals for period			
when the school is unoccupied			
Ventilated affected areas during and after the use of odorous or hazardous chemicals			ū
2. GROUNDS MAINTENANCE SUPPLIES			
2a. Stored grounds maintenance supplies in appropriate area(s)			
2b. Ensured that supplies are used and stored according to manufacturers instructions	,		
2c. Established and followed procedures to minimize exposure to fumes from supplies			۵
2d. Reviewed and followed manufacturers' guidelines for maintenance	角		
2e. Replaced portable gas cans with low-emission cans	🗖		
2f. Stored chemical products and supplies in sealed, clearly-labeled containers			-
2g. Ensured that chemicals, chemical-containing wastes, and containers a disposed of according to manufacturers' instructions	are 🐿	a	
3. DUST CONTROL		•	
3a. Installed and maintained barrier mats for entrances	🖺		
3b. Used high efficiency vacuum bags			
3c. Used proper dusting techniques			
3d. Wrapped feather dusters with a dust cloth			
3e. Cleaned air return grilles and air supply vents			

4.	FLOOR CLEANING	Yes	No	N/A	
4b.	Established and followed schedule for vacuuming and mopping floors Cleaned spills on floors promptly (as necessary)	. •		0 0	N N N N N N N N N N N N N N N N N N N
5.	DRAIN TRAPS				
5b.	Poured water down floor drains once per week (about 1 quart of water) Ran water in sinks at least once per week (about 2 cups of water) Flushed toilets once each week (if not used regularly)	=	<u> </u>	0 0	
6.	MOISTURE, LEAKS, AND SPILLS				
6a.	Checked for moldy odors	•			
6b.	Inspected ceiling tiles, floors, and walls for leaks or discoloration (may indicate periodic leaks)	_	a		
	Checked areas where moisture is commonly generated (e.g., kitchens, locker rooms, and bathrooms)	🖣	Q		
	Checked that windows, windowsills, and window frames are free of condensate				
	Checked that indoor surfaces of exterior walls and cold water pipes are free of condensate				
6f.	Ensured the following areas are free from signs of leaks and water damage Indoor areas near known roof or wall leaks	5. 🖫			
	Walls around leaky or broken windows				
	Floors and ceilings under plumbing	🖷			
	Duct interiors near humidifiers, cooling coils, and outdoor air intakes	🛢			
	COMBUSTION APPLIANCES				
7a.	Checked for odors from combustion appliances			۵	
7b	Checked appliances for backdrafting (using chemical smoke)		٥		
7c 7d	Inspected exhaust components for leaks, disconnections, or deterioration. Inspected flue components for corrosion and soot		<u> </u>		
8.	PEST CONTROL				
	. Completed the Integrated Pest Management Checklist	🗬			



- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Waste Management Checklist

Name: John Calle	m
School: ELiz Shelton	Elem School
Room or Area: All	Date Completed: 1 22 24
Signature:	

1.	WASTE MANAGEMENT	/es	No	N/A
	Ensured that waste containers are appropriate for use (for example, food waste containers should have lids)		<u> </u>	<u> </u>
	Ensured that waste containers are lined	•		ш
1c.	Ensured that waste from art, science, vocational classes, etc., are handled separately		ū	۵
1d.	Labeled recycling bins clearly			Q
1e.	Ensured number of bins and dumpsters is adequate			
1f.	Ensured appropriate location of dumpsters (i.e., away from air intakes, doors, and operable windows in relation to prevailing winds)		<u> </u>	<u> </u>
lg.	Ensured waste containers are emptied regularly		ш	
1h.	Ensured appropriate waste removal schedule			
1i.	Ensured waste is stored in a well-ventilated room	. 🗖		
li.	Ensured any exhaust fans in the room are operating properly			
	Checked waste storage areas for odors, contaminants, or signs of vermin			



- 1. Read the IAQ


 Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 this checklist for
 each ventilation
 unit in your school,
 as well as a
 copy for future
 reference.
- 3. Complete the Checklist.
 - Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Ventilation Checklist


Name: Zom Calhoun			
School: School Stem School			_
Unit Ventilator/AHU No:			
Room or Area: Date Completed:\22	24		
Signature:			
Signature.			
1. OUTDOOR AIR INTAKES			
la. Marked locations of all outdoor air intakes on a small floor plan (for	Yes	No	N/A
example, a fire escape floor plan)			
1b. Ensured that the ventilation system was on and operating in "occupied" mode			
mode		_	
ACTIVITY 1: OBSTRUCTIONS			
1c. Ensured that outdoor air intakes are clear of obstructions, debris, clogs,		П	m
or covers			
frequently block an intake)			
ACTIVITY 2: POLLUTANT SOURCES			
1e. Checked ground-level intakes for pollutant sources (dumpsters, loading			
docks, and bus-idling areas)			
1f. Checked rooftop intakes for pollutant sources (plumbing vents; kitchen, toilet, or laboratory exhaust fans; puddles; and mist from	,		
air-conditioning cooling towers)			
1g. Resolved any problems with pollutant sources located near outdoor air		_	_
intakes (e.g., relocated dumpster or extended exhaust pipe)	🗈		
ACTIVITY 3; AIRFLOW			
1h. Obtained chemical smoke (or a small piece of tissue paper or light plass	tic) 🔳		
1i. Confirmed that outdoor air is entering the intake appropriately			
2. SYSTEM CLEANLINESS			
ACTIVITY 4: AIR FILTERS			
2a. Replaced filters per maintenance schedule			Ç
2b. Shut off ventilation system fans while replacing filters (prevents dirt from	om	رس <i>و</i>	_
blowing downstream)			
2c. Vacuumed filter areas before installing new filters2d. Confirmed proper fit of filters to prevent air from bypassing (flowing		_	_
around) the air filter			C
2e. Confirmed proper installation of filters (correct direction for airflow)			C

2. SYSTEM CLEANLINESS (continued)

	IIVII X 5: DRAIN PANS		
	accumulating)	No	
2g.	Cleaned drain pans		
2h.	Checked drain pans for mold and mildew		
	TIVITY 6: COILS	П	
21.	Ensured that heating and cooling coils are clean	J	_
	TIVITY 7: AIR-HANDLING UNITS, UNIT VENTILATORS		
2j.	Ensured that the interior of air-handling unit(s) or unit ventilator (air-mixing chamber and fan blades) is clean		ū
2k.	Ensured that ducts are clean		
	TIVITY 8: MECHANICAL ROOMS		
21.	Checked mechanical room for unsanitary conditions, leaks, and spills		ū
2m	Ensured that mechanical rooms and air-mixing chambers are free of trash, chemical products, and supplies	۵	
2	CONTROLS FOR OUTDOOR AIR SUPPLY		
3a. 3h	Ensured that air dampers are at least partially open (minimum position)		<u> </u>
	for occupants		
	TIVITY 9: CONTROLS INFORMATION		
3c.	Obtained and reviewed all design inside/outside temperature and humidity		
	requirements, controls specifications, as-built mechanical drawings,	_	_
	and controls operations manuals (often uniquely designed)		
	TIVITY 10: CLOCKS, TIMERS, SWITCHES	_	_
	Turned summer-winter switches to the correct position		
	Set time clocks appropriately		u
51.	night/weekend use)		
	TIVITY 11: CONTROL COMPONENTS		
3g.	Ensured appropriate system pressure by testing line pressure at both the	۵	
2 h	occupied (day) setting and the unoccupied (night) setting	ū	
3i.			
۵1.	compressor manufacturer's recommendation (for example, when you		
3;	blow down the tank)	_	-
.رد	level (no leakage or obstructions)		
	CTIVITY 12: OUTDOOR AIR DAMPERS		_
3k	Ensured that the outdoor air damper is visible for inspection		
31.	Ensured that the recirculating relief and/or exhaust dampers are visible for inspection		. \sqsubset
3m	a. Ensured that air temperature in the indoor area(s) served by each	_	,
	outdoor air damper is within the normal operating range		<u> </u>



NOTE: It is necessary to ensure that the damper is operating properly and within the normal range to continue.




3.	CONTROLS FOR OUTDOOK AIR SUPPLY (continued)		
	of shutting off appropriate air handler	No	N/A □
	Checked that the outdoor air damper opens (at least partially with no delay) when the air handler is turned on	۵	۵
	If in heating mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 85°F		۵
3q.	If in cooling mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 60°F and mixed air thermostat is set to 45°F	â	۵
3r.	and the following items:		
	screws or bolts are tight		
	Moving parts are free of impediments (e.g., rust, corrosion)		
	my		
	Electrical wire or pneumanic tubing connects to the damper accuracy. The outside air thermostat(s) is functioning properly (e.g., in the right location, calibrated correctly)		
Pr	oceed to Activities 13–16 if the damper seems to be operating properly.		
A	CTIVITY 13: FREEZE STATS		
	. Disconnected power to controls (for automatic reset only) to test continuity across terminals	i	è
O)	R		
3t	Confirmed (if applicable) that depressing the manual reset button (usually red) trips the freeze stat (clicking sound indicates freeze stat was tripped)	ŀ	
2,,	Assessed the feasibility of replacing all manual reset freeze-stats with		
	automatic reset freeze-stats		
cl	OTE: HVAC systems with water coils need protection from the cold. The freeze-s ose the outdoor air damper and disconnect the supply air when tripped. The typi nge is 35°F to 42°F.	at ma cal tr	ty ip
A	CTIVITY 14: MIXED AIR THERMOSTATS		
31	7. Ensured that the mixed air stat for heating mode is set no higher than 65°F) C	9
Ž,	w. Ensured that the mixed air stat for cooling mode is set no lower		
,	than the room thermostat setting) C]
Á	CTIVITY 15: ECONOMIZERS		
3:	x. Confirmed proper economizer settings based on design specifications or local practices		ם נ
	OTE: The dry-bulb is typically set at 65°F or lower.		
3.	y. Checked that sensor on the economizer is shielded from direct sunlight		ם ב
3	z. Ensured that dampers operate properly (for outside air, return air, exhaust/relief air, and recirculated air), per the design specifications		ם ב
le L a	IOTE: Economizers use varying amounts of cool outdoor air to assist with the co oad of the room or rooms. There are two types of economizers, dry-bulb and enth Ory-bulb economizers vary the amount of outdoor air based on outdoor temperate and enthalpy economizers vary the amount of outdoor air based on outdoor temperated humidity level.	iaipy. 'ure,	


3. CONTROLS FOR OUTDOOR AIR SUPPLY (continued) **ACTIVITY 16: FANS** 3aa. Ensured that all fans (supply fans and associated return or relief fans) Yes No N/A that move outside air indoors continuously operate during occupied hours (even when room thermostat is satisfied)..... NOTE: If fan shuts off when the thermostat is satisfied, adjust control cycle as necessary to ensure sufficient outdoor air supply. 4. AIR DISTRIBUTION **ACTIVITY 17: AIR DISTRIBUTION** 4a. Ensured that supply and return air pathways in the existing ventilation system perform as required 4b. Ensured that passive gravity relief ventilation systems and transfer grilles between rooms and corridors are functioning NOTE: If ventilation system is closed or blocked to meet current fire codes, consult with a professional engineer for remedies. 4c. Made sure every occupied space has supply of outdoor air (mechanical system or operable windows) 4d. Ensured that supply and return vents are open and unblocked NOTE: If outlets have been blocked intentionally to correct drafts or discomfort, investigate and correct the cause of the discomfort and reopen the vents. 4e. Modified the HVAC system to supply outside air to areas without an outdoor air supply 4f. Modified existing HVAC systems to incorporate any room or zone layout and population changes 4g. Moved all barriers (for example, room dividers, large free-standing blackboards or displays, bookshelves) that could block movement of air in the room, especially those blocking air vents 4h. Ensured that unit ventilators are quiet enough to accommodate classroom activities 4i. Ensured that classrooms are free of uncomfortable drafts produced by air from supply terminals **ACTIVITY 18: PRESSURIZATION IN BUILDINGS** NOTE: To prevent infiltration of outdoor pollutants, the ventilation system is designed to maintain positive pressurization in the building. Therefore, ensure that the system, including any exhaust fans, is operating on the "occupied" cycle when doing this activity. 4j. Ensured that air flows out of the building (using chemical smoke) through windows, doors, or other cracks and holes in exterior wall (for example, floor joints, pipe openings)...... **5. EXHAUST SYSTEMS** ACTIVITY 19: EXHAUST FAN OPERATION 5a. Checked (using chemical smoke) that air flows into exhaust fan grille(s) \square If fans are running but air is not flowing toward the exhaust intake, check for the following:

· Inoperable dampers

· Broken fan belt

Obstructed, leaky, or disconnected ductwork
Undersized or improperly installed fan





5. EXHAUST SYSTEMS (continued)

ACTIVITY 20: EXHAUST AIRFLOW

NOTE: Prevent migration of indoor contaminants from areas such as bathroon and labs by keeping them under negative pressure (as compared to surrounding	ns, kit g spa	chen. ces).	5,
5b. Checked (using chemical smoke) that air is drawn into the room from adjacent spaces	Yes		N/A
Stand outside the room with the door slightly open while checking airflow high the door opening (see "How to Measure Airflow").	n and	low i	n
5c. Ensured that air is flowing toward the exhaust intake			Q
ACTIVITY 21: EXHAUST DUCTWORK 5d. Checked that the exhaust ductwork downstream of the exhaust fan (which under positive pressure) is sealed and in good condition	ı is 🕿	<u> </u>	۵
6. QUANTITY OF OUTDOOR AIR			
ACTIVITY 22: OUTDOOR AIR MEASUREMENTS AND CALCULATI	ONS		
NOTE: Refer to "How to Measure Airflow" for techniques.			
6a. Measured the quantity of outdoor air supplied (22a) to each ventilation unit	a		
6b. Calculated the number of occupants served (22b) by the ventilation unit under consideration	🗀		
6c. Divided outdoor air supply (22a) by the number of occupants (22b) to determine the existing quantity of outdoor air supply per person (22c)	🗅		
ACTIVITY 23: ACCEPTABLE LEVELS OF OUTDOOR AIR QUANTI	TIES		
6d. Compared the existing outdoor air per person (22c) to the recommended levels in Table 1			
6e. Corrected problems with ventilation units that supplied inadequate quantities of outdoor air to ensure that outdoor air quantities (22c) meet the recommended levels in Table 1			




- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Walkthrough Inspection Checklist

Name:		Zohn	Calhom		_
School:	Pliz	Shriften	Elem	5 choor	
Room or	Area:	M	Date Com	pleted: 1/22/24	
		7		•	
Signature			70		

4	GROUND LEVEL			
				N/A
1a.	Ensured that ventilation units operate properly			
1b.	Ensured there are no obstructions blocking air intakes			0
lc.	Checked for nests and droppings near outdoor air intakes	🛥		
	Determined that dumpsters are located away from doors, windows, and outdoor air intakes	•	۵	
le.	Checked potential sources of air contaminants near the building (chimneys, stacks, industrial plants, exhaust from nearby buildings)	•	П	
1f.	Ensured that vehicles avoid idling near outdoor air intakes	T		
1g.	Minimized pesticide application			
1h.	Ensured that there is proper drainage away from the building (including roof downspouts)	_		۵
1i.	Ensured that sprinklers spray away from the building and outdoor			
11.	air intakes	□	ά	
1j.	Ensured that walk-off mats are used at exterior entrances and that		_	_
	they are cleaned regularly	D		
	ROOF ile on the roof, consider inspecting the HVAC units (use the Ventilation Ch	ecklis	:t).	
	Ensured that the roof is in good condition			
2a.	Checked for evidence of water ponding	.		
2b.	Checked that ventilation units operate properly (air flows in)		_	
20.	Ensured that exhaust fans operate properly (air flows out)	9		1 0
2u.	Ensured that air intakes remain open, even at minimum setting			
26. 2f	Checked for nests and droppings near outdoor air intakes	G		ı 🗆
21. 2a	Ensured that air from plumbing stacks and exhaust outlets flows away			
25.	from outdoor air intakes			j 🗆
3.	ATTIC			
3.9	Checked for evidence of roof and plumbing leaks		Ε	ם נ
3h	Checked for birds and animal nests			ם נ
4.	GENERAL CONSIDERATIONS			
4a	Ensured that temperature and humidity are maintained within acceptable ranges	î	ו כ	ם ב
4h	Ensured that no obstructions exist in supply and exhaust vents	.		ם ב
4c	Checked for odors	🗷		ם ב
4d	. Checked for signs of mold and mildew growth	🖥) (ם ב

4. (GENERAL CONSIDERATIONS (continued)	No	N/A
4e.	Checked for signs of water damage		ū
4f.	Checked for evidence of pests and obvious food sources		
4g.	Noted and reviewed all concerns from school occupants		
5.	BATHROOMS AND GENERAL PLUMBING		
	Ensured that bathrooms and restrooms have operating exhaust fans		
	Water is poured down floor drains once per week (approx. 1 quart of water)		
	Water is poured into sinks at least once per week (about 2 cups of water)		
	Toilets are flushed at least once per week		
6.	MAINTENANCE SUPPLIES		
6a.	Ensured that chemicals are used only with adequate ventilation and when		_
	building is unoccupied		
6b.	Ensured that vents in chemical and trash storage areas are operating	_	_
	properly	ū	
6c.	Ensured that portable fuel containers are properly closed		
6d.	Ensured that power equipment, like snowblowers and lawn mowers, have been serviced and maintained according to manufacturers' guidelines	۵	۵
7.	COMBUSTION APPLIANCES		
	Checked for combustion gas and fuel odors		
7a. 7h	Ensured that combustion appliances have flues or exhaust hoods		
70.	Checked for leaks, disconnections, and deterioration		
7d.	Ensured there is no soot on inside or outside of flue components		
	OTHER		
8a.	Checked for peeling and flaking paint (if the building was built before	_	_
	1980, this could be a lead hazard)	<u> </u>	
8b.	Determined date of last radon test		



- Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.


Integrated Pest Management Checklist


Na	ame: John Cally un		
Sc	hool: are shulton Elem. School		
Ro	pom or Area: Date Completed:		
Si	gnature:	~ 	_
<u></u>			
1.	OFFICIAL POLICY STATEMENT Yes	No	N//
1a.	Developed or located the school's official policy statement for integrated pest management (IPM)	۵	
2.	DESIGNATING PEST MANAGEMENT ROLES		
	Assigned and trained a qualified person to be the pest manager		
2b.	Involved decision makers in the IPM program Educated students and staff (the occupants of the building) about IPM		u
	and asked them to keep their areas clean and free of clutter		
2d.	Encouraged parents to learn about IPM practices and implement them at home		
2e.	Developed a program to educate and train all IPM participants		
2f.	Included language about IPM into contracts with pest management professionals	Q	٥
3.	SETTING PEST MANAGEMENT OBJECTIVES		
3a.	Set appropriate pest management objectives for school buildings (such as		
	preventing pests from interfering with students' learning environment and preserving the integrity of the building structure)		
3b.	Set appropriate pest management objectives for school grounds (such as	_	
	providing safe playing areas and the best athletic surfaces possible)		
4.	INSPECTING, IDENTIFYING, AND MONITORING		
4a.			
/h	food, water, and harborage sites	٥	
4c.	Pinpointed the source of any current pest problems		
4d	Monitored to determine the extent of pest problems and to estimate pest	_	_
A .	populations		_
46.	sanitation efforts) to prevent or resolve any pest problems		•
4f.			

estimate pest population levels and identify evidence of pests and

potential habitat

5.	SETTING ACTION THRESHOLDS			
5a.	Evaluated all available data obtained through inspecting, identifying, and monitoring		No ≜	N/A
	Determined how many pests the school buildings, grounds, and occupants can tolerate			
5c.	Set action thresholds			
6.	PREVENTIVE STRATEGIES			
INI	DOOR SITES			
ба.	Implemented appropriate strategies to prevent pests from inhabiting the following	owin	g are	eas:
	• Entryways			
	• Classrooms	9		
	• Gymnasiums			
	• Locker rooms			
	• Offices			
	Staff lounges			
	• Bathrooms			
	• Food preparation and serving areas			
	Rooms with extensive plumbing			
	Maintenance areas			
	• Other			
οτ	TTDOOR SITES			
6b.	Implemented appropriate strategies to prevent pests from inhabiting the foll	owii	ng ar	eas:
	• Playgrounds			u
•	Parking lots			<u> </u>
	Lawns and athletic fields		0	<u> </u>
	Teaching gardens or greenhouses			
	Loading docks			
	• Dumpsters			a
	• Areas with ornamental shrubs and trees	. 🖢		
	• Other	. 🖫		
7.	PESTICIDE USE AND STORAGE			
7a.	Explored alternative pest management methods before concluding that		П	
	pesticides were necessary	•	_	_
	Ensured that pest management professionals integrate IPM into their pest management methods			
7c.	Identified the least toxic, target-specific chemical (or pesticide			
	formulation) that is the most effective to address the pest problem,			
	preferably as baitsand granules			
	Reviewed and followed all label instructions on pesticides and learned how to properly apply and handle these chemicals	🖿		
7e	Used spot-treatment (or bait, crack, and crevice applications) to apply			
	pesticides whenever possible and only treated the obviously infested			
	plants in the area	-	<u></u>	
7f.	Used protective clothing or equipment when applying pesticides	u	ш	•
7g	. Placed all pesticides in tamper-resistant bait boxes or locations that are	_		
	inaccessible to children and non-target species			•






7.	PESTICIDE USE AND STORAGE (cont.)			
7h.	Locked or fastened lids of all bait boxes and placed bait away from the runway of the box	s	No	N/A
7i.	Applied pesticides when occupants were not present or in areas where they would not be exposed to the chemicals)		
7j.	Ensured that school occupants (students and staff) are notified of upcoming pesticide applications through posted notices and/or letters	1		
7k.	through letters)		
71.	Kept copies of current pesticide labels and information on pesticides easily accessible	1	Q	
	Stored pesticides off site or in areas that are locked and accessible only to designated personnel	3		
7n.	Ensured that storage areas are adequately ventilated and are located away from areas prone to flooding or where spills or leaks may contaminate the environment	B	Q	
7o.	Ensured that flammable liquids are stored away from ignition sources			
	Ensured that pesticides are stored in their original containers and all lids are securely fastened	3	۵	
7q.	Ensured that air in the storage space cannot mix with the air in the central ventilation system	3		
8.	EVALUATING RESULTS AND RECORD KEEPING			
8a.	Ensured that accurate, up-to-date records of IPM practices and a pest management log for each property are kept	•		
8b.	Ensured that pesticide records necessary to meet all state, local, and school board requirements are maintained			
8c.	Ensured that each log book contains the following items: Copy of the pest management plan Service schedules for maintenance of buildings and grounds Current EPA-registered labels		000	
	• Current Material Safety Data Sheets (MSDS) for each pesticide project			

• Pest surveillance data sheets

• Diagram noting the location of pest activity, traps, and bait stations.......



- 1. Read the IAQ

 Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Food Service Checklist

Name: 50hm Calhon	<u>m</u>	
School: Eliz Shelton		hoov
Room or Area:	Date Completed: _	1/22/24
A -		
Signature:		

1. COOKING AREA

٤.	COURING ARLA		
	Determined that local exhaust fans operate properly (note if fans are excessively noisy)		N/A
1b.	Checked for odors near cooking, preparation, and eating areas		
1c.	Ensured that exhaust fans are used whenever cooking, washing dishes, and cleaning		
1d.	Determined that gas appliances function properly		
1e.	Verified that gas appliances are vented outdoors		
	Ensured there are no combustion gas or natural gas odors, leaks, backdrafting, or headaches when gas appliances are used		
lg.	Ensured that kitchen is clean after use	u	_
1h.	Checked for signs of microbiological growth in the kitchen, including the upper walls and ceiling (for example, mold, slime, and algae)	۵	ū
li.	Selected biocides registered by EPA (if required), followed the manufacturer's directions for use, and carefully reviewed the method of application	, _	
1.2	Verified the kitchen is free of plumbing and ceiling leaks (signs include	_	
lj.	stains, discoloration, and damp areas)		
2.	FOOD HANDLING AND STORAGE		
	Checked food preparation, cooking, and storage areas for signs of insects and vermin (for example, feces or remains)	ı 🗅	ū
	Stored leftovers in well-sealed containers with no traces of food on outside surfaces	1 🗅	ū
2c.	Ensured that food preparation, cooking, and storage practices are sanitary	0	
2d.	Disposed of food scraps properly and removed crumbs		
2e.	Cleaned counters with soap and water or a disinfectant (according to		
_	school policy)		
2f.	Swept and wet mopped floors		
3.	WASTE MANAGEMENT		
3a.	Selected and placed waste in appropriate containers		
3b.	Ensured that containers' lids are securely closed		
3c.	if possible		
	Stored waste containers in a well-ventilated area		
3e.	Ensured that dumpsters are properly located (away from air intake vents, operable windows, and food service doors in relation to	. _	
	prevailing winds)		

4.	DELIVERIES	Yes	No	N/A
	Instructed vendors to avoid idling their engines during deliveries	🖭		Q
4b.	Posted a sign prohibiting vehicles from idling their engines in receiving areas	🗖		
4c.	Ensured that doors or air barriers are closed between receiving area and kitchen	_		

