

- 1. Read the IAQ
  Backgrounder and
  the Background
  Information for
  this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  the checklist for
  future reference.
- 3. Complete the Checklist.
  - Check the "yes,"
     "no," or
     "not applicable"
     box beside each
     item. (A "no"
     response requires
     further attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

# **Building and Grounds Maintenance Checklist**

Name: Jo	hn Calhou	$\cap$	
School: She	Hon High	School	
Room or Area:	ALL	Date Completed: .	1/22/24
Signature:	<u> </u>	2	
<b>J</b>			

1.	BUILDING MAINTENANCE SUPPLIES	9S	No	N/A
la.	Developed appropriate procedures and stocked supplies for spill control		ū	ū
1b.	Reviewed supply labels	ì		
1c.	Ensured that air from chemical and trash storage areas vents to		_	_
	the outdoors	,		
1d.	Stored chemical products and supplies in sealed, clearly labeled			
1	Containers			_
	Ensured that supplies are being used according to manufacturers'	-		
11.	instructions			
1g.	Ensured that chemicals, chemical-containing wastes, and containers are	_		
-	disposed of according to manufacturers' instructions	ð		
1h.	Substituted less- or non-hazardous materials (where possible)			
1i.	Scheduled work involving odorous or hazardous chemicals for periods	_		
	when the school is unoccupied	#	ш	
lj.	Ventilated affected areas during and after the use of odorous or hazardous chemicals			
	nazardous chemicais	_	_	_
2.	GROUNDS MAINTENANCE SUPPLIES			
2a.	Stored grounds maintenance supplies in appropriate area(s)			
2b.	Ensured that supplies are used and stored according to manufacturers'			
	instructions			
2c.	Established and followed procedures to minimize exposure to fumes			
2.1	from supplies  Reviewed and followed manufacturers' guidelines for maintenance			_
2a.	Replaced portable gas cans with low-emission cans	<u>-</u>	•	_
2e. 2f.		_	_	_
41.	containers	J		а
2g.	Ensured that chemicals, chemical-containing wastes, and containers are			
-8	disposed of according to manufacturers' instructions			
•	DUCT CONTROL			
	DUST CONTROL	_	*	
З̀а.	Installed and maintained barrier mats for entrances			_
	Used high efficiency vacuum bags		<u> </u>	_
	Used proper dusting techniques		0	
	Wrapped feather dusters with a dust cloth			_
3e.	Cleaned air return grilles and air supply vents	•		

4.	FLOOR CLEANING Yes	No	N/A
4b.	Established and followed schedule for vacuuming and mopping floors  Cleaned spills on floors promptly (as necessary)	0	<u> </u>
5.	DRAIN TRAPS		
5b.	Poured water down floor drains once per week (about 1 quart of water)	<u> </u>	000
6.	MOISTURE, LEAKS, AND SPILLS		
6а.	Checked for moldy odors		
6b.	Inspected ceiling tiles, floors, and walls for leaks or discoloration (may indicate periodic leaks)	0	
	Checked areas where moisture is commonly generated (e.g., kitchens, locker rooms, and bathrooms)	a	۵
6d.	Checked that windows, windowsills, and window frames are free of condensate		
	Checked that indoor surfaces of exterior walls and cold water pipes are free of condensate		
6f.	Ensured the following areas are free from signs of leaks and water damage: Indoor areas near known roof or wall leaks  Walls around leaky or broken windows  Floors and ceilings under plumbing  Duct interiors near humidifiers, cooling coils, and outdoor air intakes		0000
7.	COMBUSTION APPLIANCES		
7b. 7c.	Checked for odors from combustion appliances		000
8.	PEST CONTROL		
8a.	Completed the Integrated Pest Management Checklist		



- 1. Read the IAQ

  Backgrounder and the Background Information for this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  the checklist for
  future reference.
- 3. Complete the Checklist.
  - Check the "yes,"
     "no," or
     "not applicable"
     box beside each
     item. (A "no"
     response
     requires further
     attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAO Coordinator.

# **Waste Management Checklist**

Name: JOHN Co	Thoun		
School: Shelton	Heah	School	
Room or Area: All	Date Co	mpleted: 1.22-24	
		impieted:	
Signature:	500	·	

1.	WASTE MANAGEMENT	Yes	No	N/A
	Ensured that waste containers are appropriate for use (for example, food waste containers should have lids)			۵
	Ensured that waste containers are lined	🗷		
	Ensured that waste from art, science, vocational classes, etc., are handled separately	•		
1d.	Labeled recycling bins clearly			
1e.	Ensured number of bins and dumpsters is adequate	,, 🕏		
	Ensured appropriate location of dumpsters (i.e., away from air intakes, doors, and operable windows in relation to prevailing winds)			
1g.	Ensured waste containers are emptied regularly	🖣		
1h.	Ensured appropriate waste removal schedule			
1i.	Ensured waste is stored in a well-ventilated room	🗖		
lj.	Ensured any exhaust fans in the room are operating properly	🗖		
	Checked waste storage areas for odors, contaminants, or signs of vermin			Q)




- 1. Read the IAQ
  Backgrounder and
  the Background
  Information for
  this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  this checklist for
  each ventilation
  unit in your school,
  as well as a
  copy for future
  reference.
- 3. Complete the Checklist.
  - Check the "yes,"
     "no," or
     "not applicable"
     box beside each
     item. (A "no"
     response
     requires further
     attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

# **Ventilation Checklist**


	Stehn Belling		
Na	me:		
Scł	nool: Melton figh School		
Un	it Ventilator/AHU No:		
	om or Area:Date Completed:		
Sig	mature:		
_			
	OUTDOOR AIR INTAKES		
1a.	Marked locations of all outdoor air intakes on a small floor plan (for	No	N/A
11.	example, a fire escape floor plan)	42	ш
10.	mode	Q	
	TIVITY 1: OBSTRUCTIONS		
lc.	Ensured that outdoor air intakes are clear of obstructions, debris, clogs,	П	
14	Installed corrective devices as necessary (e.g., if snowdrifts or leaves	_	_
Įu.	frequently block an intake)		
	TIVITY 2: POLLUTANT SOURCES		
le.	Checked ground-level intakes for pollutant sources (dumpsters, loading docks, and bus-idling areas)	П	
1f	Checked rooftop intakes for pollutant sources (plumbing vents; kitchen,	_	_
	toilet, or laboratory exhaust fans; puddles; and mist from		
	air-conditioning cooling towers)		
lg.	Resolved any problems with pollutant sources located near outdoor air intakes (e.g., relocated dumpster or extended exhaust pipe)		
	mitakes (e.g., resocated dumpster of extended exhaust pipe)	_	_
AC	TIVITY 3: AIRFLOW		
lh.	Obtained chemical smoke (or a small piece of tissue paper or light plastic)		
1i.	Confirmed that outdoor air is entering the intake appropriately		
_	OVOTERA OLE ABILIBIECO		
2.	SYSTEM CLEANLINESS		
	TIVITY 4: AIR FILTERS	_	_
	Replaced filters per maintenance schedule		
26.	Shut off ventilation system fans while replacing filters (prevents dirt from blowing downstream)	۵	
2c.	Vacuumed filter areas before installing new filters		
	Confirmed proper fit of filters to prevent air from bypassing (flowing	_	_
	around) the air filter		_
2e.	Confirmed proper installation of filters (correct direction for airflow)		

# 2. SYSTEM CLEANLINESS (continued)

	TIVITY 5: DRAIN PANS		
	accumulating)	No □	N/A
2g.	Cleaned drain pans		
	Checked drain pans for mold and mildew		
AC'	TIVITY 6: COILS	_	_
2i.	Ensured that heating and cooling coils are clean		
	TIVITY 7: AIR-HANDLING UNITS, UNIT VENTILATORS		
2j.	Ensured that the interior of air-handling unit(s) or unit ventilator (air-mixing chamber and fan blades) is clean		۵
2k.	Ensured that ducts are clean		
	TIVITY 8: MECHANICAL ROOMS		
21.	Checked mechanical room for unsanitary conditions, leaks, and spills		
2m.	Ensured that mechanical rooms and air-mixing chambers are free of trash, chemical products, and supplies		
3.	CONTROLS FOR OUTDOOR AIR SUPPLY		
3a.	Ensured that air dampers are at least partially open (minimum position)		a
3Ъ.	Ensured that minimum position provides adequate outdoor air for occupants		
	TIVITY 9: CONTROLS INFORMATION		
3c.	Obtained and reviewed all design inside/outside temperature and humidity requirements, controls specifications, as-built mechanical drawings, and controls operations manuals (often uniquely designed)		Q
	TIVITY 10: CLOCKS, TIMERS, SWITCHES		
AC 24	Turned summer-winter switches to the correct position		
3e.	Set time clocks appropriately		
3f.	Ensured that settings fit the actual schedule of building use (including night/weekend use)	۵	
	TIVITY 11: CONTROL COMPONENTS		
3g.	Ensured appropriate system pressure by testing line pressure at both the occupied (day) setting and the unoccupied (night) setting		
3h.	Checked that the line dryer prevents moisture buildup		
3i.	compressor manufacturer's recommendation (for example, when you	-	_
2;	blow down the tank)	0	_
3j.	level (no leakage or obstructions)		
	CTIVITY 12: OUTDOOR AIR DAMPERS	_	
3k.	Ensured that the outdoor air damper is visible for inspection		
	for inspection		
3m	a. Ensured that air temperature in the indoor area(s) served by each outdoor air damper is within the normal operating range		1
		_	



NOTE: It is necessary to ensure that the damper is operating properly and within the normal range to continue.




3.	CONTROLS FOR OUTDOOR AIR SUPPLY (continued)			
	of shutting off appropriate air handler		No	N/A
	Checked that the outdoor air damper opens (at least partially with no delay) when the air handler is turned on		0	۵
_	If in heating mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 85°F.  If in cooling mode, checked that the outdoor air damper goes to its minimum	ם	•	۵
	position (without completely closing) when the room thermostat is set to 60°F and mixed air thermostat is set to 45°F			۵
Sr.	<ul> <li>The damper actuator links to the damper shaft, and any linkage set screws or bolts are tight</li></ul>		000	
	location, calibrated correctly)	9		
	oceed to Activities $13-16$ if the damper seems to be operating properly.			
3s.	CTIVITY 13: FREEZE STATS  Disconnected power to controls (for automatic reset only) to test continuity across terminals			
OF 3t.				•
3u	Assessed the feasibility of replacing all manual reset freeze-stats with automatic reset freeze-stats		٥	
clc	OTE: HVAC systems with water coils need protection from the cold. The freeze- ose the outdoor air damper and disconnect the supply air when tripped. The ty nge is 35°F to 42°F.	sta vic	ıt ma al tri	y P
A	CTIVITY 14: MIXED AIR THERMOSTATS			
3v	Ensured that the mixed air stat for heating mode is set no higher than 65°F			•
3v	v. Ensured that the mixed air stat for cooling mode is set no lower than the room thermostat setting			
A	CTIVITY 15: ECONOMIZERS			
33	c. Confirmed proper economizer settings based on design specifications or local practices	. 🖷		ם
	OTE: The dry-bulb is typically set at 65°F or lower.			
3 <u>3</u>	<ul> <li>Checked that sensor on the economizer is shielded from direct sunlight</li> <li>Ensured that dampers operate properly (for outside air, return air, exhaust/relief air, and recirculated air), per the design specifications</li> </ul>			_
lo D as	TOTE: Economizers use varying amounts of cool outdoor air to assist with the bad of the room or rooms. There are two types of economizers, dry-bulb and en bry-bulb economizers vary the amount of outdoor air based on outdoor temper and enthalpy economizers vary the amount of outdoor air based on outdoor ten but humidity level.	coe the atu	oling ulpy. tre,	

#### 3. CONTROLS FOR OUTDOOR AIR SUPPLY (continued) ACTIVITY 16: FANS 3aa. Ensured that all fans (supply fans and associated return or relief fans) that move outside air indoors continuously operate during occupied Yes No N/A hours (even when room thermostat is satisfied)..... NOTE: If fan shuts off when the thermostat is satisfied, adjust control cycle as necessary to ensure sufficient outdoor air supply. 4. AIR DISTRIBUTION **ACTIVITY 17: AIR DISTRIBUTION** 4a. Ensured that supply and return air pathways in the existing ventilation system perform as required ..... 4b. Ensured that passive gravity relief ventilation systems and transfer grilles between rooms and corridors are functioning ..... NOTE: If ventilation system is closed or blocked to meet current fire codes, consult with a professional engineer for remedies. 4c. Made sure every occupied space has supply of outdoor air (mechanical system or operable windows) ..... 4d. Ensured that supply and return vents are open and unblocked ..... NOTE: If outlets have been blocked intentionally to correct drafts or discomfort, investigate and correct the cause of the discomfort and reopen the vents. 4e. Modified the HVAC system to supply outside air to areas without an outdoor air supply ...... 4f. Modified existing HVAC systems to incorporate any room or zone layout and population changes ..... 4g. Moved all barriers (for example, room dividers, large free-standing blackboards or displays, bookshelves) that could block movement of air in the room, especially those blocking air vents ..... 4h. Ensured that unit ventilators are quiet enough to accommodate classroom activities ..... 4i. Ensured that classrooms are free of uncomfortable drafts produced by air from supply terminals ..... **ACTIVITY 18: PRESSURIZATION IN BUILDINGS** NOTE: To prevent infiltration of outdoor pollutants, the ventilation system is designed to maintain positive pressurization in the building. Therefore, ensure that the system, including any exhaust fans, is operating on the "occupied" cycle when doing this activity. 4i. Ensured that air flows out of the building (using chemical smoke) through windows, doors, or other cracks and holes in exterior wall (for example, floor joints, pipe openings)....... 5. EXHAUST SYSTEMS **ACTIVITY 19: EXHAUST FAN OPERATION** 5a. Checked (using chemical smoke) that air flows into exhaust fan grille(s) ..... $\square$ If fans are running but air is not flowing toward the exhaust intake, check for the following: · Inoperable dampers · Obstructed, leaky, or disconnected ductwork · Undersized or improperly installed fan

· Broken fan belt





# 5. EXHAUST SYSTEMS (continued)

# **ACTIVITY 20: EXHAUST AIRFLOW**

NOTE: Prevent migration of indoor contaminants from areas such as bathrood and labs by keeping them under negative pressure (as compared to surroundi	ms, kil ng spa	chen. ces).	5,
5b. Checked (using chemical smoke) that air is drawn into the room from adjacent spaces	_	No •	N/A
Stand outside the room with the door slightly open while checking airflow hig the door opening (see "How to Measure Airflow").	gh and	low i	n
5c. Ensured that air is flowing toward the exhaust intake			Q
ACTIVITY 21: EXHAUST DUCTWORK  5d. Checked that the exhaust ductwork downstream of the exhaust fan (whic under positive pressure) is sealed and in good condition	h is 🗖	۵	۵
6. QUANTITY OF OUTDOOR AIR			
ACTIVITY 22: OUTDOOR AIR MEASUREMENTS AND CALCULAT	IONS	•	
NOTE: Refer to "How to Measure Airflow" for techniques.			
WILL THE THE TAXABLE PARTY OF THE PARTY OF T	🗅		
6b. Calculated the number of occupants served (22b) by the ventilation unit under consideration	🗅		
6c. Divided outdoor air supply (22a) by the number of occupants (22b) to determine the existing quantity of outdoor air supply per person (22c)			۵
ACTIVITY 23: ACCEPTABLE LEVELS OF OUTDOOR AIR QUANTI	ITIES		
6d. Compared the existing outdoor air per person (22c) to the recommended levels in Table 1	1		۵
6e. Corrected problems with ventilation units that supplied inadequate quantities of outdoor air to ensure that outdoor air quantities (22c) meet the recommended levels in Table 1		•	۵



- 1. Read the IAQ Backgrounder and the Background Information for this checklist.
- 2. Keep the Background Information and make a copy of the checklist for future reference.
- 3. Complete the Checklist.
  - · Check the "yes," "no," or "not applicable" box beside each item. (A "no" response requires further attention.)
  - · Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.


# Walkthrough Inspection Checklist

Na	me: John Calloun		-
Scl	hool: Sheltm High		_
Ro	om or Area: Ml Date Completed:/21/14		
0:-	6		
518	gnature:		_
L			
1.	GROUND LEVEL Yes	Na 1	11/A
	Ensured that ventilation units operate properly	No 1	V/A
1a.	Ensured there are no obstructions blocking air intakes	ū	_
10.	Checked for nests and droppings near outdoor air intakes		
1d.	Determined that dumpsters are located away from doors, windows, and		
	outdoor air intakes	ū	
le.	Checked potential sources of air contaminants near the building		
	(chimneys, stacks, industrial plants, exhaust from nearby buildings)	ם	
	Ensured that vehicles avoid idling near outdoor air intakes		
Ig.	Ensured that there is proper drainage away from the building (including	_	_
111.	roof downspouts)		
1i.	Ensured that sprinklers spray away from the building and outdoor		
	air intakes		4
lj.	Ensured that walk-off mats are used at exterior entrances and that they are cleaned regularly		
2.	ROOF		
	ile on the roof, consider inspecting the HVAC units (use the Ventilation Checklis	t).	
		ٔ ا	
2a.	Ensured that the roof is in good condition	_	٥
	Checked that ventilation units operate properly (air flows in)		ū
	Ensured that exhaust fans operate properly (air flows out)		
2e.	Ensured that air intakes remain open, even at minimum setting		
2f.	Checked for nests and droppings near outdoor air intakes		
2g.	Ensured that air from plumbing stacks and exhaust outlets flows away	_	_
	from outdoor air intakes	U	
3.	ATTIC		
3a.	Checked for evidence of roof and plumbing leaks		
3b.	Checked for birds and animal nests		
4.	GENERAL CONSIDERATIONS		
4a.	Ensured that temperature and humidity are maintained within	_	_
	acceptable ranges		
	Ensured that no obstructions exist in supply and exhaust vents		
40	Charved for odore		

4c. Checked for odors .....

4d. Checked for signs of mold and mildew growth ......

4. (	GENERAL CONSIDERATIONS (continued)	No	N/A
4f.	Checked for signs of water damage		000
5.	BATHROOMS AND GENERAL PLUMBING		
	Ensured that bathrooms and restrooms have operating exhaust fans		a D
	Water is poured down floor drains once per week (approx. 1 quart of water)		
	Water is poured into sinks at least once per week (about 2 cups of water)	<u> </u>	
6.	MAINTENANCE SUPPLIES		
	Ensured that chemicals are used only with adequate ventilation and when building is unoccupied		۵
6b.	Ensured that vents in chemical and trash storage areas are operating properly		
6c.	Ensured that portable fuel containers are properly closed		
6d.	Ensured that power equipment, like snowblowers and lawn mowers, have been serviced and maintained according to manufacturers' guidelines		۵
7.	COMBUSTION APPLIANCES		
7a.	Checked for combustion gas and fuel odors		
7b.	Ensured that combustion appliances have flues or exhaust hoods		
7c. 7d.	Checked for leaks, disconnections, and deterioration		
8.	OTHER	1	
8a.	Checked for peeling and flaking paint (if the building was built before 1980, this could be a lead hazard)	) c	ı 🗅
8b.	Determined date of last radon test	• -	



- 1. Read the IAQ
  Backgrounder and
  the Background
  Information for
  this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  the checklist for
  future reference.
- 3. Complete the Checklist.
  - Check the "yes,"
     "no," or
     "not applicable"
     box beside each
     item. (A "no"
     response
     requires further
     attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

# **Integrated Pest Management Checklist**

Name:	John Ca	houn			
School:	Shelton	High	5 Choor		
Room or Area:	All	Dat	e Completed: _	1-22-24	
Signature:		75	· >		
Signature					

1.	OFFICIAL POLICY STATEMENT	es	No	N/A
1a	. Developed or located the school's official policy statement for integrated pest management (IPM)			ū
2.	DESIGNATING PEST MANAGEMENT ROLES			
2a 2b	Involved decision makers in the IPM program		<u> </u>	0
	Educated students and staff (the occupants of the building) about IPM and asked them to keep their areas clean and free of clutter	ב		
	Encouraged parents to learn about IPM practices and implement them at home	_		
2e 2f	Developed a program to educate and train all IPM participants  Included language about IPM into contracts with pest management professionals		Q	u 0
3.	SETTING PEST MANAGEMENT OBJECTIVES			
	Set appropriate pest management objectives for school buildings (such as preventing pests from interfering with students' learning environment and preserving the integrity of the building structure)	•		a
3b	<ul> <li>Set appropriate pest management objectives for school grounds (such as providing safe playing areas and the best athletic surfaces possible)</li> </ul>		0	ū
4.	. INSPECTING, IDENTIFYING, AND MONITORING			
	n. Inspected all buildings and grounds for pest evidence, entry points, food, water, and harborage sites			
41	o. Identified potential pest habitats in buildings and grounds	Ď		Q.
40	e. Pinpointed the source of any current pest problems			
	d. Monitored to determine the extent of pest problems and to estimate pest populations			۵
46	e. Developed plans to modify habitat (for example, exclusion, repair, and sanitation efforts) to prevent or resolve any pest problems		۵	•
41			۵	_

5.	SETTING ACTION THRESHOLDS		
5a.	Evaluated all available data obtained through inspecting, identifying, and monitoring	No <b>≜</b>	N/A □
	Determined how many pests the school buildings, grounds, and occupants can tolerate		۵
5c.	Set action thresholds		<u>u</u>
6.	PREVENTIVE STRATEGIES		
INI	OOOR SITES		
6a.	Implemented appropriate strategies to prevent pests from inhabiting the followin	g are	eas:
	• Entryways	_	ā
	• Classrooms		<u> </u>
	• Gymnasiums		
	• Locker rooms		
	• Offices		
	• Staff lounges		
	• Bathrooms		
	• Food preparation and serving areas		
	• Rooms with extensive plumbing	<u> </u>	_
	• Maintenance areas	<u> </u>	
	• Other		
οι	TDOOR SITES		
6b.	Implemented appropriate strategies to prevent pests from inhabiting the following	ıg ar	eas:
	• Playgrounds		
	• Parking lots	_	0
	• Lawns and athletic fields		<b>_</b>
	• Teaching gardens or greenhouses		
	• Loading docks	0	<u> </u>
	• Dumpsters	<u> </u>	
	Areas with ornamental shrubs and trees      Other	ā	0
7	PESTICIDE USE AND STORAGE		
	Explored alternative pest management methods before concluding that		
	pesticides were necessary		
	Ensured that pest management professionals integrate IPM into their pest management methods		۵
7c.	Identified the least toxic, target-specific chemical (or pesticide formulation) that is the most effective to address the pest problem,	_	_
	preferably as baitsand granules		
	Reviewed and followed all label instructions on pesticides and learned how to properly apply and handle these chemicals		
7e	Used spot-treatment (or bait, crack, and crevice applications) to apply		
	pesticides whenever possible and only treated the obviously infested		
	plants in the area		<u> </u>
7f.	Used protective clothing or equipment when applying pesticides	Ų	
7g	Placed all pesticides in tamper-resistant bait boxes or locations that are inaccessible to children and non-target species		0





7.	PESTICIDE USE AND STORAGE (cont.)		
7h.	Locked or fastened lids of all bait boxes and placed bait away from the runway of the box	No	N/A
7i.	Applied pesticides when occupants were not present or in areas where they would not be exposed to the chemicals		
7j.	Ensured that school occupants (students and staff) are notified of upcoming pesticide applications through posted notices and/or letters		Q
7k.	Ensured that parents are notified of upcoming pesticide applications through letters		
71.	Kept copies of current pesticide labels and information on pesticides		۵
	Stored pesticides off site or in areas that are locked and accessible only to designated personnel		
7n.	Ensured that storage areas are adequately ventilated and are located away from areas prone to flooding or where spills or leaks may contaminate the environment	a	a
7o.	Ensured that flammable liquids are stored away from ignition sources		
	Ensured that pesticides are stored in their original containers and all lids are securely fastened		
7q.	Ensured that air in the storage space cannot mix with the air in the central ventilation system		
8.	EVALUATING RESULTS AND RECORD KEEPING		
	Ensured that accurate, up-to-date records of IPM practices and a pest management log for each property are kept	<u> </u>	а
	Ensured that pesticide records necessary to meet all state, local, and school board requirements are maintained	۵	0
8c.	Ensured that each log book contains the following items:		
	Copy of the pest management plan      Service schedules for maintenance of buildings and grounds	ם	_
	Current EPA-registered labels		
	Current Material Safety Data Sheets (MSDS) for each pesticide project		
	• Pest surveillance data sheets		_
	• Diagram noting the location of pest activity, traps, and bait stations		



# Name: John Calwan School: Shelton Hugh School Room or Area: All Date Completed: (22/124) Signature:

**Food Service Checklist** 

## Instructions

- 1. Read the IAQ

  Backgrounder and the Background Information for this checklist.
- 2. Keep the
  Background
  Information and
  make a copy of
  the checklist for
  future reference.
- 3. Complete the Checklist.
  - Check the "yes,"
     "no," or
     "not applicable"
     box beside each
     item. (A "no"
     response
     requires further
     attention.)
  - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

# 1. COOKING AREA

	Determined that local exhaust fans operate properly (note if fans are excessively noisy)	No □	N/A
1b.	Checked for odors near cooking, preparation, and eating areas		
	Ensured that exhaust fans are used whenever cooking, washing dishes, and cleaning	0	<u> </u>
1 <b>d</b> .	Determined that gas appliances function properly	ם	
1e.	Verified that gas appliances are vented outdoors		_
	Ensured there are no combustion gas or natural gas odors, leaks, backdrafting, or headaches when gas appliances are used	0	0
1g.	Ensured that kitchen is clean after use		
	Checked for signs of microbiological growth in the kitchen, including the upper walls and ceiling (for example, mold, slime, and algae)		
1i.	Selected biocides registered by EPA (if required), followed the manufacturer's directions for use, and carefully reviewed the		
	method of application	_	<b>—</b>
lj.	Verified the kitchen is free of plumbing and ceiling leaks (signs include stains, discoloration, and damp areas)		
2.	FOOD HANDLING AND STORAGE		
	Checked food preparation, cooking, and storage areas for signs of insects and vermin (for example, feces or remains)	۵	
2b.	Stored leftovers in well-sealed containers with no traces of food on outside surfaces		۵
2c.	Ensured that food preparation, cooking, and storage practices are sanitary •		
2d.	Disposed of food scraps properly and removed crumbs		
2e.	Cleaned counters with soap and water or a disinfectant (according to school policy)		
2f.	Swept and wet mopped floors		
3.	WASTE MANAGEMENT		
3a.			_
3b.	Ensured that containers' lids are securely closed		
3c.	if possible		. –
	Stored waste containers in a well-ventilated area		
J.	vents, operable windows, and food service doors in relation to prevailing winds)	ı 🗅	ı 🗅

	DELIVERIES	Yes	No	N/A
4a.	Instructed vendors to avoid idling their engines during deliveries	<b>9</b>		
	Posted a sign prohibiting vehicles from idling their engines in receiving areas	🗅		
4c.	Ensured that doors or air barriers are closed between receiving area and kitchen	, 📤		ū

