


- 1. Read the IAO
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response requires
 further attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Building and Grounds Maintenance Checklist

Name:	John	Calhon	n _		
School:	00TH 4	411 Eleme	otary	Schoo	سا د
Room or Area:	AVI		Completed:	1/22	24
		700	<u></u>		
Signature:		0 0	$\overline{}$	<u></u>	

1.	BUILDING MAINTENANCE SUPPLIES	es	No	N/A
1a.	Developed appropriate procedures and stocked supplies for spill control			Ġ
1b.	Reviewed supply labels	n.		
	Ensured that air from chemical and trash storage areas vents to the outdoors	Đ		
	Stored chemical products and supplies in sealed, clearly labeled containers	h		
le.	Researched and selected the safest products available			
1f.	instructions			Q
_	Ensured that chemicals, chemical-containing wastes, and containers are disposed of according to manufacturers' instructions			<u> </u>
1h.	Substituted less- or non-hazardous materials (where possible)			
li.	Scheduled work involving odorous or hazardous chemicals for periods when the school is unoccupied			
1j.	Ventilated affected areas during and after the use of odorous or hazardous chemicals	B		ם
2.	GROUNDS MAINTENANCE SUPPLIES			
2a.	Stored grounds maintenance supplies in appropriate area(s)			
2b.	Ensured that supplies are used and stored according to manufacturers' instructions	_		a
	Established and followed procedures to minimize exposure to fumes from supplies			
	Reviewed and followed manufacturers' guidelines for maintenance			ū
2e.	Replaced portable gas cans with low-emission cans			
2f.	containers			□
2g.	Ensured that chemicals, chemical-containing wastes, and containers are disposed of according to manufacturers' instructions			
3.	DUST CONTROL		•	
За.				
3b.	. Used high efficiency vacuum bags			
3c.	. Used proper dusting techniques			
	. Wrapped feather dusters with a dust cloth			ū
3e.	. Cleaned air return grilles and air supply vents			

4. I	FLOOR CLEANING	/es	No	N/A	
4Ъ.	Established and followed schedule for vacuuming and mopping floors Cleaned spills on floors promptly (as necessary)		000		
5. I	DRAIN TRAPS				E I I I
5b.	Poured water down floor drains once per week (about 1 quart of water) Ran water in sinks at least once per week (about 2 cups of water) Flushed toilets once each week (if not used regularly)	. •	0 0	000	0 0
6.	MOISTURE, LEAKS, AND SPILLS				
6a.	Checked for moldy odors				
	Inspected ceiling tiles, floors, and walls for leaks or discoloration (may indicate periodic leaks)		a		
6c.	Checked areas where moisture is commonly generated (e.g., kitchens, locker rooms, and bathrooms)	_	ū	0	
	Checked that windows, windowsills, and window frames are free of condensate				
6e.	Checked that indoor surfaces of exterior walls and cold water pipes are free of condensate	. •	۵	u	
61.	Indoor areas near known roof or wall leaks		О	ū	
	Walls around leaky or broken windows	🛊			
	Floors and ceilings under plumbing Duct interiors near humidifiers, cooling coils, and outdoor air intakes	🛢			
7.	COMBUSTION APPLIANCES				
	Checked for odors from combustion appliances	🛍			
7b.	Checked appliances for backdrafting (using chemical smoke)				
7c.	The state of the s	🛢			
8.	PEST CONTROL				
	Completed the Integrated Pest Management Checklist	🖷		ロ	




- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Waste Management Checklist

Name:	Jom	Calhour	<u> </u>	
School:	NH HTGO	Ebem.	School	
Room or Area:	AU		ompleted:	1/22/24
		7		·
Signature:				

1.	WASTE MANAGEMENT	Yes	No	N/A
	Ensured that waste containers are appropriate for use (for example, food waste containers should have lids)		<u> </u>	0
	Ensured that waste containers are lined	., 🗷	Ц	ш
	Ensured that waste from art, science, vocational classes, etc., are handled separately		<u> </u>	0
1d.	Labeled recycling bins clearly	., 🔳	u	Ц
1e.	Ensured number of bins and dumpsters is adequate	🗖		
1f.	Ensured appropriate location of dumpsters (i.e., away from air intakes, doors, and operable windows in relation to prevailing winds)	T	ā	<u> </u>
1g.	Ensured waste containers are emptied regularly	📦	u	
1h.	Ensured appropriate waste removal schedule	🖀		
1i.	Ensured waste is stored in a well-ventilated room	🖸		
li.	Ensured any exhaust fans in the room are operating properly	🛡		
1k.	Checked waste storage areas for odors, contaminants, or signs of vermin	•		



- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 this checklist for
 each ventilation
 unit in your school,
 as well as a
 copy for future
 reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Ventilation Checklist

	Tal Alleman		
N	fame: OWN COMPANY		_
S	chool: South Hull Elim School		
บ	Init Ventilator/AHU No:		_
R	coom or Area: Date Completed:/22/2	4	_
8	ignature:		
1.	OUTDOOR AIR INTAKES		
1a	. Marked locations of all outdoor air intakes on a small floor plan (for	No	N/A
1 %	example, a fire escape floor plan)	•	Ч
10	mode		
	CONTRACT 1. ADSTRUCTIONS		
	CTIVITY 1: OBSTRUCTIONS Ensured that outdoor air intakes are clear of obstructions, debris, clogs,		
	or covers		
1d	l. Installed corrective devices as necessary (e.g., if snowdrifts or leaves frequently block an intake)		
	CTIVITY 2: POLLUTANT SOURCES		
le	c. Checked ground-level intakes for pollutant sources (dumpsters, loading docks, and bus-idling areas)		
1 f	Checked rooftop intakes for pollutant sources (plumbing vents; kitchen,		
	toilet, or laboratory exhaust fans; puddles; and mist from air-conditioning cooling towers)		
١g	Resolved any problems with pollutant sources located near outdoor air		_
	intakes (e.g., relocated dumpster or extended exhaust pipe)	Q	_
	CTIVITY 3: AIRFLOW		
11	n. Obtained chemical smoke (or a small piece of tissue paper or light plastic)		-
li	. Confirmed that outdoor air is entering the intake appropriately	u	_
2	. SYSTEM CLEANLINESS		
A	CTIVITY 4: AIR FILTERS		
28	a. Replaced filters per maintenance schedule		
21	b. Shut off ventilation system fans while replacing filters (prevents dirt from blowing downstream)		. [
20	c. Vacuumed filter areas before installing new filters		
2	d. Confirmed proper fit of filters to prevent air from bypassing (flowing around) the air filter	ū	[

2e. Confirmed proper installation of filters (correct direction for airflow).......

2. SYSTEM CLEANLINESS (continued)

	IIVITY 5: DRAIN PANS			
	accumulating)		ú	N/A
2g.	Cleaned drain pans			
2h.	Checked drain pans for mold and mildew			ū
	TIVITY 6: COILS	_		
2i.	Ensured that heating and cooling coils are clean		_	u
	TIVITY 7: AIR-HANDLING UNITS, UNIT VENTILATORS			
2j.	Ensured that the interior of air-handling unit(s) or unit ventilator (air-mixing chamber and fan blades) is clean		۵	
2k.	Ensured that ducts are clean			
	TIVITY 8: MECHANICAL ROOMS	_		
21.	Checked mechanical room for unsanitary conditions, leaks, and spills			
	Ensured that mechanical rooms and air-mixing chambers are free of trash,			
	chemical products, and supplies		Q	
3.	CONTROLS FOR OUTDOOR AIR SUPPLY			
3a.	Ensured that air dampers are at least partially open (minimum position)			
3b.	Ensured that minimum position provides adequate outdoor air for occupants			
۸C	TIVITY 9: CONTROLS INFORMATION			
	Obtained and reviewed all design inside/outside temperature and humidity			
50.	requirements, controls specifications, as-built mechanical drawings,			
	and controls operations manuals (often uniquely designed)	. 🕲		
AC	TIVITY 10: CLOCKS, TIMERS, SWITCHES	-	_	
3d.	Turned summer-winter switches to the correct position	🚆		
3e.	Set time clocks appropriately	•		
3f.	Ensured that settings fit the actual schedule of building use (including night/weekend use)	. 🖿		
AC	TIVITY 11: CONTROL COMPONENTS			
3g.	Ensured appropriate system pressure by testing line pressure at both the occupied (day) setting and the unoccupied (night) setting	🖜		
21	Checked that the line dryer prevents moisture buildup			
3H.	Replaced control system filters at the compressor inlet based on the			
31.	compressor manufacturer's recommendation (for example, when you blow down the tank)	🖨		
2;	Set the line pressure at each thermostat and damper actuator at the proper			
.ارد	level (no leakage or obstructions)	🐿		
	CTIVITY 12: OUTDOOR AIR DAMPERS	18		
3k.	Ensured that the outdoor air damper is visible for inspection	🖭	L.,	
31.	Ensured that the recirculating relief and/or exhaust dampers are visible for inspection	😰		
3m	. Ensured that air temperature in the indoor area(s) served by each			
	outdoor air damper is within the normal operating range	📭		




NOTE: It is necessary to ensure that the damper is operating properly and within the normal range to continue.



3.	CONTROLS FOR OUTDOOR AIR SUPPLY (continued)		
	of shutting off appropriate air handler	No □	N/A
	Checked that the outdoor air damper opens (at least partially with no delay) when the air handler is turned on	a	a
-	If in heating mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 85°F.		۵
_	If in cooling mode, checked that the outdoor air damper goes to its minimum position (without completely closing) when the room thermostat is set to 60°F and mixed air thermostat is set to 45°F		۵
3r.	The damper actuator links to the damper shaft, and any linkage set screws or bolts are tight	۵	
	 Moving parts are free of impediments (e.g., rust, corrosion) Electrical wire or pneumatic tubing connects to the damper actuator 		
	The outside air thermostat(s) is functioning properly (e.g., in the right location, calibrated correctly)	0	٥
Pro	oceed to Activities $13-16$ if the damper seems to be operating properly.		
AC 3s.	Disconnected power to controls (for automatic reset only) to test continuity across terminals		*
	Confirmed (if applicable) that depressing the manual reset button (usually red) trips the freeze stat (clicking sound indicates freeze stat was tripped)		
3u	Assessed the feasibility of replacing all manual reset freeze-stats with automatic reset freeze-stats		
clc	OTE: HVAC systems with water coils need protection from the cold. The freeze-st ose the outdoor air damper and disconnect the supply air when tripped. The typic nge is 35°F to 42°F.	at ma cal tri	y ip
A	CTIVITY 14: MIXED AIR THERMOSTATS		
	Ensured that the mixed air stat for heating mode is set no higher than 65°F		•
3v	v. Ensured that the mixed air stat for cooling mode is set no lower than the room thermostat setting	ı 🗆	
A 0	CTIVITY 15: ECONOMIZERS Confirmed proper economizer settings based on design specifications or local practices	ı =	ם נ
	OTE: The dry-bulb is typically set at 65°F or lower.		
3 y 3 z	y. Checked that sensor on the economizer is shielded from direct sunlight		
lo D as	OTE: Economizers use varying amounts of cool outdoor air to assist with the content of the room or rooms. There are two types of economizers, dry-bulb and entholory-bulb economizers vary the amount of outdoor air based on outdoor temperate and enthalpy economizers vary the amount of outdoor air based on outdoor temperate that the content of the cont	oling alpy. ure,	

3. CONTROLS FOR OUTDOOR AIR SUPPLY (continued) **ACTIVITY 16: FANS** 3aa. Ensured that all fans (supply fans and associated return or relief fans) Yes No N/A that move outside air indoors continuously operate during occupied hours (even when room thermostat is satisfied)..... NOTE: If fan shuts off when the thermostat is satisfied, adjust control cycle as necessary to ensure sufficient outdoor air supply. 4. AIR DISTRIBUTION **ACTIVITY 17: AIR DISTRIBUTION** 4a. Ensured that supply and return air pathways in the existing ventilation system perform as required..... 4b. Ensured that passive gravity relief ventilation systems and transfer grilles between rooms and corridors are functioning NOTE: If ventilation system is closed or blocked to meet current fire codes, consult with a professional engineer for remedies. 4c. Made sure every occupied space has supply of outdoor air (mechanical system or operable windows) 4d. Ensured that supply and return vents are open and unblocked NOTE: If outlets have been blocked intentionally to correct drafts or discomfort, investigate and correct the cause of the discomfort and reopen the vents. 4e. Modified the HVAC system to supply outside air to areas without an outdoor air supply 4f. Modified existing HVAC systems to incorporate any room or zone layout and population changes 4g. Moved all barriers (for example, room dividers, large free-standing blackboards or displays, bookshelves) that could block movement of air in the room, especially those blocking air vents 4h. Ensured that unit ventilators are quiet enough to accommodate classroom activities 4i. Ensured that classrooms are free of uncomfortable drafts produced by air from supply terminals ACTIVITY 18: PRESSURIZATION IN BUILDINGS NOTE: To prevent infiltration of outdoor pollutants, the ventilation system is designed to maintain positive pressurization in the building. Therefore, ensure that the system, including any exhaust fans, is operating on the "occupied" cycle when doing this activity. 4j. Ensured that air flows out of the building (using chemical smoke) through windows, doors, or other cracks and holes in exterior wall (for example, floor joints, pipe openings)...... 5. EXHAUST SYSTEMS ACTIVITY 19: EXHAUST FAN OPERATION 5a. Checked (using chemical smoke) that air flows into exhaust fan grille(s) \Box If fans are running but air is not flowing toward the exhaust intake, check for the following: Inoperable dampers · Obstructed, leaky, or disconnected ductwork · Undersized or improperly installed fan

· Broken fan belt





5. EXHAUST SYSTEMS (continued)

ACTIVITY 20: EXHAUST AIRFLOW

NOTE: Prevent migration of indoor contaminants from areas such as bathrooms, kitch and labs by keeping them under negative pressure (as compared to surrounding space	hens es).	ζ,
5b. Checked (using chemical smoke) that air is drawn into the room from adjacent spaces	No	N/A
Stand outside the room with the door slightly open while checking airflow high and lot the door opening (see "How to Measure Airflow").	ow ii	1
5c. Ensured that air is flowing toward the exhaust intake		
ACTIVITY 21: EXHAUST DUCTWORK 5d. Checked that the exhaust ductwork downstream of the exhaust fan (which is under positive pressure) is sealed and in good condition	O.	۵
6. QUANTITY OF OUTDOOR AIR		
ACTIVITY 22: OUTDOOR AIR MEASUREMENTS AND CALCULATIONS		
NOTE: Refer to "How to Measure Airflow" for techniques.		
6a. Measured the quantity of outdoor air supplied (22a) to each ventilation unit		٥
6b. Calculated the number of occupants served (22b) by the ventilation unit under consideration		-
6c. Divided outdoor air supply (22a) by the number of occupants (22b) to determine the existing quantity of outdoor air supply per person (22c)□		Q
ACTIVITY 23: ACCEPTABLE LEVELS OF OUTDOOR AIR QUANTITIES		
6d. Compared the existing outdoor air per person (22c) to the recommended levels in Table 1	•	
6e. Corrected problems with ventilation units that supplied inadequate quantities of outdoor air to ensure that outdoor air quantities (22c) meet the recommended levels in Table 1	-	



- 1. Read the IAQ


 Backgrounder and the Background Information for this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Walkthrough Inspection Checklist

Name:	John	Chellrou	<u>n</u>	 	
School:	THE HALL &	flem	Schoor	 <i>.</i>	I .
Room or Area: _	All	Date	Completed: _	 22	24
Signature:		20	<u> </u>		

1	. GROUND LEVEL	Yes	No	N/A
1	a. Ensured that ventilation units operate properly			
1	b. Ensured there are no obstructions blocking air intakes	🖥		
1	c. Checked for nests and droppings near outdoor air intakes	🐿		
1	d. Determined that dumpsters are located away from doors, windows, and outdoor air intakes	_		۵
	 e. Checked potential sources of air contaminants near the building (chimneys, stacks, industrial plants, exhaust from nearby buildings) 		<u> </u>	
1	f. Ensured that vehicles avoid idling near outdoor air intakes	₹	0	
1	g. Minimized pesticide application	=		
1	h. Ensured that there is proper drainage away from the building (including roof downspouts)			
1	i. Ensured that sprinklers spray away from the building and outdoor air intakes	ם		
1	 Ensured that walk-off mats are used at exterior entrances and that they are cleaned regularly 	🖜	<u> </u>	
	2. ROOF			
,	While on the roof, consider inspecting the HVAC units (use the Ventilation Ch	ecklis	st).	
2	2a. Ensured that the roof is in good condition	🖫		ı 🗆
2	2c. Checked that ventilation units operate properly (air flows in)	👤		
2	2d. Ensured that exhaust fans operate properly (air flows out)	T		
2	Re. Ensured that air intakes remain open, even at minimum setting	🚍		
2	2f. Checked for nests and droppings near outdoor air intakes	🗷	' _) D
2	2g. Ensured that air from plumbing stacks and exhaust outlets flows away from outdoor air intakes			ı 🗅
;	3. ATTIC			
	3a. Checked for evidence of roof and plumbing leaks			. –
	3b. Checked for birds and animal nests			ם נ
	4. GENERAL CONSIDERATIONS			
	4a. Ensured that temperature and humidity are maintained within acceptable ranges			ם כ
	4b. Ensured that no obstructions exist in supply and exhaust vents		1 (7
	4c. Checked for odors			ם ב
	4d. Checked for signs of mold and mildew growth	🗑		ם כ

4. (GENERAL CONSIDERATIONS (continued) Yes	No	N/A
4f.	Checked for signs of water damage	0	000
5.	BATHROOMS AND GENERAL PLUMBING		
	Ensured that bathrooms and restrooms have operating exhaust fans		ū
	Water is poured down floor drains once per week (approx. 1 quart of water)		
	Water is poured into sinks at least once per week (about 2 cups of water)	٥	0
6.	MAINTENANCE SUPPLIES		
	Ensured that chemicals are used only with adequate ventilation and when building is unoccupied		
6b.	Ensured that vents in chemical and trash storage areas are operating properly	۵	
6с.	Ensured that portable fuel containers are properly closed		
6d.	Ensured that power equipment, like snowblowers and lawn mowers, have been serviced and maintained according to manufacturers' guidelines		
7.	COMBUSTION APPLIANCES		
7a.	Checked for combustion gas and fuel odors		
7b.	Ensured that combustion appliances have flues or exhaust hoods		_
7c. 7d.	Ensured there is no soot on inside or outside of flue components		_
		1	
	OTHER		
8a.	Checked for peeling and flaking paint (if the building was built before 1980, this could be a lead hazard)	i	
8b.	Determined date of last radon test	ı 🗆	




- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- 4. Return the checklist portion of this document to the IAQ Coordinator.

Integrated Pest Management Checklist

Na	me: 30hn Calhoun		
Sci	hool: Booth Hill glam - School		
	om or Area: Date Completed: 1/22/24		
Sig	gnature:		— [
1.	OFFICIAL POLICY STATEMENT	No	N1//
10	Developed or located the school's official policy statement for integrated	140	IN/F
ra.	pest management (IPM)		
2.	DESIGNATING PEST MANAGEMENT ROLES		
	Assigned and trained a qualified person to be the pest manager		
	Involved decision makers in the IPM program		
2c.	Educated students and staff (the occupants of the building) about IPM and asked them to keep their areas clean and free of clutter		
2đ.	Encouraged parents to learn about IPM practices and implement them		Ī
	at home		
2e.	Developed a program to educate and train all IPM participants		
2f.	Included language about IPM into contracts with pest management professionals	ū	
3.	SETTING PEST MANAGEMENT OBJECTIVES		
3a.	Set appropriate pest management objectives for school buildings (such as		
	preventing pests from interfering with students' learning environment		
214	and preserving the integrity of the building structure)	_	
JU.	providing safe playing areas and the best athletic surfaces possible)		
4.	INSPECTING, IDENTIFYING, AND MONITORING		
4a.	Inspected all buildings and grounds for pest evidence, entry points,		
	food, water, and harborage sites		
	Identified potential pest habitats in buildings and grounds		
4c.	Pinpointed the source of any current pest problems		u
4a.	populations		
4e.	Developed plans to modify habitat (for example, exclusion, repair, and		
	sanitation efforts) to prevent or resolve any pest problems		•
4f.	Established a monitoring program that consists of routine inspections to estimate pest population levels and identify evidence of pests and		
	potential habitat		
	~		

5.	SETTING ACTION THRESHOLDS		
5a.	Evaluated all available data obtained through inspecting, identifying, and monitoring	No	N/A
	Determined how many pests the school buildings, grounds, and occupants can tolerate		۵
5c.	Set action thresholds		
6.	PREVENTIVE STRATEGIES		
	OOOR SITES		
ба.	Implemented appropriate strategies to prevent pests from inhabiting the follow	ng ar	eas:
	• Entryways	u	u
	• Classrooms		
	Gymnasiums		
	• Locker rooms		
	• Offices		
	• Staff lounges		
	• Bathrooms		
	• Food preparation and serving areas		
	• Rooms with extensive plumbing		_
	Maintenance areas		<u> </u>
	• Other		
ου	TDOOR SITES		
6b.	Implemented appropriate strategies to prevent pests from inhabiting the follow	ing ai	eas:
	• Playgrounds	ū	
	Parking lots	ū	ם
	• Lawns and athletic fields		
	Teaching gardens or greenhouses		
	• Loading docks	<u> </u>	ם
	• Dumpsters		<u> </u>
	Areas with ornamental shrubs and trees Other	<u> </u>	0
7	PESTICIDE USE AND STORAGE		
7a.	Explored alternative pest management methods before concluding that pesticides were necessary		
71	Ensured that pest management professionals integrate IPM into their		
	pest management methods		
7c.	Identified the least toxic, target-specific chemical (or pesticide formulation) that is the most effective to address the pest problem,		
	preferably as baitsand granules		
7d	Reviewed and followed all label instructions on pesticides and learned	_	_
	how to properly apply and handle these chemicals		
7e	Used spot-treatment (or bait, crack, and crevice applications) to apply		
	pesticides whenever possible and only treated the obviously infested		
	plants in the area		_
7f.	Used protective clothing or equipment when applying pesticides		
7g	Placed all pesticides in tamper-resistant bait boxes or locations that are	i 🗆	
	inaccessible to children and non-target species	_	





7.	PESTICIDE USE AND STORAGE (cont.)		
7h.	Locked or fastened lids of all bait boxes and placed bait away from the runway of the box	No	N/A
7i.	Applied pesticides when occupants were not present or in areas where they would not be exposed to the chemicals	o.	0
7j.	Ensured that school occupants (students and staff) are notified of upcoming pesticide applications through posted notices and/or letters		۵
7k.	Ensured that parents are notified of upcoming pesticide applications through letters	Q	۵
71.	Kept copies of current pesticide labels and information on pesticides easily accessible		
	Stored pesticides off site or in areas that are locked and accessible only to designated personnel		
7n.	Ensured that storage areas are adequately ventilated and are located away from areas prone to flooding or where spills or leaks may contaminate the environment	ם	
7o.	Ensured that flammable liquids are stored away from ignition sources	ū	
7p.	Ensured that pesticides are stored in their original containers and all lids are securely fastened	۵	
7q.	Ensured that air in the storage space cannot mix with the air in the central ventilation system		
8.	EVALUATING RESULTS AND RECORD KEEPING		
8a.	Ensured that accurate, up-to-date records of IPM practices and a pest management log for each property are kept	_	
	Ensured that pesticide records necessary to meet all state, local, and school board requirements are maintained		
8c.	Ensured that each log book contains the following items:	_	
	• Copy of the pest management plan		
	• Service schedules for maintenance of buildings and grounds	J	
	 Current EPA-registered labels Current Material Safety Data Sheets (MSDS) for each pesticide project 	<u> </u>	
	Pest surveillance data sheets	<u> </u>	
	• Diagram noting the location of pest activity, traps, and bait stations	ū	_
	- Dingram nound are received of back searing and and ages against an		



- 1. Read the IAQ
 Backgrounder and
 the Background
 Information for
 this checklist.
- 2. Keep the
 Background
 Information and
 make a copy of
 the checklist for
 future reference.
- 3. Complete the Checklist.
 - Check the "yes,"
 "no," or
 "not applicable"
 box beside each
 item. (A "no"
 response
 requires further
 attention.)
 - Make comments in the "Notes" section as necessary.
- Return the checklist portion of this document to the IAQ Coordinator.

Food Service Checklist

I	DOU DELAICE OFFICERISE		
Na	me: John Galliann		
	hool: BOOTH HILL ELENSCHOOL		
	oom or Area: AM Date Completed: 1/22/2	ч	
Sig	gnature:		
L			
1.	COOKING AREA		
1a.	Determined that local exhaust fans operate properly (note if fans are	s No	N/A
	excessively noisy)		
Ib.	Checked for odors near cooking, preparation, and eating areas		_
lc.	Ensured that exhaust fans are used whenever cooking, washing dishes, and cleaning		
1.3	Determined that gas appliances function properly		ā
Id.	Verified that gas appliances are vented outdoors		. 0
16. 1f.	Ensured there are no combustion gas or natural gas odors, leaks, back-		
11.	drafting, or headaches when gas appliances are used		
1g.	Ensured that kitchen is clean after use	ı u	
1h.	Checked for signs of microbiological growth in the kitchen, including		_
	the upper walls and ceiling (for example, mold, slime, and algae)	ı u	
li.	Selected biocides registered by EPA (if required), followed the		
	manufacturer's directions for use, and carefully reviewed the	• •	
٠.	method of application Verified the kitchen is free of plumbing and ceiling leaks (signs include	,	<u></u>
lj.	stains, discoloration, and damp areas)		
	, and the same of		
	FOOD HANDLING AND STORAGE		
2a.	Checked food preparation, cooking, and storage areas for signs of insects		_
	and vermin (for example, feces or remains)		
2b.	Stored leftovers in well-sealed containers with no traces of food on outside		
	surfaces	_	
2c.	Ensured that food preparation, cooking, and storage practices are sanitary		
2d.	Disposed of food scraps properly and removed crumbs	_	. —
2e.	Cleaned counters with soap and water or a disinfectant (according to school policy)		1 0
2f.	·) O
3.	WASTE MANAGEMENT		
3a.	Selected and placed waste in appropriate containers		-
3b.	Ensured that containers' lids are securely closed) [
3c.	Separated food waste and food-contaminated items from other wastes,		, _
	if possible		
3d	Stored waste containers in a well-ventilated area		<u>.</u> _

3e. Ensured that dumpsters are properly located (away from air intake vents, operable windows, and food service doors in relation to

prevailing winds)

	DELIVERIES			N/A
4a.	Instructed vendors to avoid idling their engines during deliveries	🖭		
	Posted a sign prohibiting vehicles from idling their engines in receiving areas	🗅		۵
4c.	Ensured that doors or air barriers are closed between receiving area and kitchen	📤	۵	

